



# Compliance Statement

## Unscreened Category 6 ISO/IEC, EN & TIA/EIA Communication Cable

**Krugel Exim Identification P/N KE400U23**

**Category 6, Unscreened**

**100 W, 4 Twisted Pairs, 23 AWG, Flame Retardant, PVC Sheath, Copper Cable**

**Krugel Exim s.r.o.**

**Rybníčná 38/H**

**831 06 Bratislava 35, Slovak Republic**

***Compliance Statement No. 108443***

*This Unscreened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2007, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 and IEC Cable Standard 61156-5, and the requirements of CENELEC Cable Standard EN 50288-6-1. Flame Retardancy is verified according to IEC 60332-1-2. The cable has EMC Performance Rating 5. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance of Qualification Testing performed at 6 or 12 month intervals.*

Hoersholm, 8<sup>th</sup> December 2008

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 8<sup>th</sup> December 2008

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager